



City of Groton, CT
Department of Planning & Economic Development

TO: PLV
MBF
WIP: 3-1922

Application Review Sheet

Distribution Date: June 17, 2019

Return by Date: June 27, 2019

Application Information

Address: 107 Thames Street

Project Description: Shellfishing business

Contact Person: Dennis Goderre Telephone: 860-446-4169

Distribution List

Building Department
Fire Department
Health Department
Highway Department
Park and Recreation

Police Department
Utility – Electric
Utility – Sewer/Water
Other: _____

Project Considerations/Information:

Please review revised plans addressing your comments.

This application meets our Department/Agency requirements: Yes No

Review Comments (if none state 'none'):

Please see attached comments
D. Zito

**GROTON UTILITIES
ELECTRIC
SITE PLAN REVIEW SHEET**

Title of Plan Shellfishing Business Latest Revision Date _____
Location 107 Thames St W.I.P. # 3-1922
Engineer Docko, Inc Phone # 860-572-8939
Reviewed By David Zito 446-4036 Date of Review 6/20/18

- ~~1. Plan not approved. Electrical requirements mentioned in project narrative call for the ultimate service to be 600amp. The need for a 600amp service was not discussed at our May 7th meeting. Services 600amp and above require a padmount transformer. GU also will need to know if the service will be single or three phase. Engineer will need to provide electrical load, service size and voltage information in order for GU to determine size and type of service required. Please see highlighted attachment. Plan approved. All potential conflicts resolved as of 6/20/19~~
2. Groton Utilities to provide layout and proposal of underground electric upon receipt of final plans and electric loads.