

Goderre, Dennis

From: Goderre, Dennis
Sent: Friday, August 30, 2019 3:02 PM
To: Joe Banks; 'Curtis.Whipple@arcadis.com'; 'Dave Sullivan'
Subject: Fire Comments: West Side

1. Rear driveway turnaround should show dimensions and turning movements of the City's fire apparatus to confirm movement
2. No center island should be constructed.
3. No parking allowed in the turn area of the parent drop off area. Show turning movement of fire apparatus to confirm parked vehicles will not interfere with fire entry.

This constitutes all our comments.

Sincerely,

Dennis G. Goderre RLA, AICP CUD
City Planner

City of Groton
295 Meridian Street
Groton, CT 06340
Direct: 860-446-4169
Cell: 860-235-2041
goderred@cityofgroton-ct.gov